wictotouic



Operating manual mic+ Ultrasonic Sensors with two switching outputs

 mic+25/DD/TC
 mic+25/EE/TC

 mic+35/DD/TC
 mic+35/EE/TC

 mic+130/DD/TC
 mic+130/EE/TC

 mic+340/DD/TC
 mic+340/EE/TC

 mic+600/DD/TC
 mic+600/EE/TC

Product description

- The mic+ sensor with two switching outputs offer a non-contact measurement of the distance to an object. Depending on the adjusted detect distance the switching outputs are set.
- All settings are done with two push-buttons and a three-digit LED display (Touch-Control)
- Light emitting diodes (three-colour LEDs) indicate the switching status.
- The output functions are changeable from NOC to NCC.
- The sensors are adjustable manually using the numerical LED display or via Teach-in procedure.
- Useful additional functions are set in the Add-on-menu
- Using the LinkControl adapter (optional accessory) all TouchControl and additional sensor parameter settings may be made by a Windows software.

Important instructions for assembly and application

All employee and plant safety-relevant measures must be taken prior to assembly, start-up, or maintenance work (see operating manual for the entire plant and the operator instruction of the plant).

The sensors are not considered as safety equipment and may not be used to ensure human or machine safety!

The mic+ sensors indicate a **blind zone**, in which the distance cannot be measured. The **operating range** indicates the distance of the sensor that can be applied with normal reflectors with sufficient function reserve. When using good reflectors, such as a calm water surface, the sensor can also be used up to its **maximum range**. Objects that strongly absorb (e.g. plastic foam) or diffusely reflect sound (e.g. pebble stones) can also reduce the defined operating range.

Synchronisation

If the assembly distances shown in fig.1 for two or more sensors are exceeded the integrated synchronisation should be used. Connect Sync/Com-channels (pin 5) of all sensors (10 maximum).

	Ļ	
	ightharpoons	D⊶a
D.IIIII]]	≥0.35 m	≥2.50 m
	≥0.40 m	≥2.50 m
	≥1.10 m	≥8.00 m
D[[[]]	≥2.00 m	≥18.00 m
	≥4.00 m	≥30.00 m

Fig. 1: Minimal assembly distances without synchronisation or multiplex mode.

Multiplex mode

The Add-on-menu allows to assign an individual address »01« to »10« to each sensor connected via the Sync/Com-channel (Pin5). The sensors perform the ultrasonic measurement sequentially from low to high address. Therefore any influence between the sensors is rejected.

The address »00« is reserved to synchronisation mode and deactivates the multiplex mode. (To use synchronised mode all sensors must be set to address »00«.)

Assembly instructions

- Assemble the sensor at the installation location.
- Plug in the connector cable to the M12 connector.

2 • 1 • 3 • 5 • 4	11	colour
1	+U _B	brown
3	-U _B	blue
4	D2	black
2	D1	white
5	Sync/Com	grey

Fig. 2: Pin assignment with view onto sensor plug and colour coding of the microsonic connection cable.

Start-up

mic+ sensors are delivered factory made with the following settings:

- Switching outputs on NOC
- Detecting distances at operating range and half operating range
- Measurement range set to maximum range

Set the parameters of the sensor manually or use the Teach-in procedure to adjust the switching points.




Fig. 3: TouchControl

Maintenance


mic+ sensors work maintenance free. Small amounts of dirt on the surface do not influence function. Thick layers of dirt and cakedon dirt affect sensor function and therefore must be removed.


Note


- mic+ sensors have internal temperature compensation. Because the sensors heat up on their own, the temperature compensation reaches its optimum working point after approx. 30 minutes of operation.
- During normal operating mode, a yellow LED signals that the corresponding switching output is set.
- During normal operating mode, the measured distance value is displayed on the LED display in mm (up to 999 mm) or cm (from 100 cm). Scale switches automatically and is indicated by a point on top of the digits.
- During Teach-in mode, the hysteresis value is set back to factory settings.
- If no objects are placed within the detection zone the LED display shows »- --«.
- If no push-buttons are pressed for 20 seconds during parameter setting mode, the parameter changes are saved and the sensor returns to normal operating mode.


Show parameters

Tapping push-button T1 shortly during normal operating mode shows »PAr« on the LED display. Each time you tap push-button T1 the actual settings of the switching outputs are displayed.











For use only in industrial with a Listed (CYJV/7) cable/connector mum 290 mA, in the final installation.









2014/30/FI

