wictotouic



Operating Manual

Ultrasonic sensor with one analogue output

pico+15/TF/I pico+25/TF/I pico+35/TF/I pico+100/TF/I pico+15/TF/U pico+25/TF/U pico+35/TF/U pico+100/TF/U

Product description

The pico+ sensor offers a non-contact measurement of the distance to an object that has to be present within the sensor's detection zone. Depending on the set window limits, a distance-proportional analogue signal is output.

The ultrasonic transducer surface of the pico+ sensors is laminated with a PTFE film. The transducer itself is sealed against the housing by a joint ring. This composition permits measurement in up to 0,5 bar over pressure. The window limits of the analogue output and its characteristic can be adjusted via Teach-in procedure. Two LEDs indicate operation and the state of the analogue output.

Safety instructions

- Read the operating manual prior to start-up.
- Connection, installation and adjustments may only be carried out by qualified staff.
- No safety component in accordance with the EU Machine Directive, use in the area of personal and machine protection not permitted

Use for intended purpose only

pico+ ultrasonic sensors are used for non-contact detection of objects.

Installation

→ Mount the sensor at the place of fitting.

For the pico+100/TF we recommend not to use for mounting the first 5 mm of the M22 thread on the side of the transducer.

→ Connect a connection cable to the M12 device plug, see Fig. 1.

2 • 1 3 • 5 • 4		colour
1	+U _B	brown
3	−U _B	blue
4	-	black
2	I/U	white
5	Com	arev

Fig. 1: Pin assignment with view onto sensor plug and colour coding of the microsonic connection cables

Start-up

- → Connect the power supply.
- → Carry out sensor adjustment in accordance with Diagram 1.

Factory setting

Rising analogue characteristic curve between the blind zone and the operating range.

Multifunctional input »Com« set to »Teach-in«.

Synchronisation

If the assembly distance falls below the values shown in Fig. 2, the internal synchronization should be used. For this purpose set the switched outputs of all sensors in accordance to Diagram 1 at first. Then set the multifunctional output »Com« to »synchronization« (see »Further settings«, Diagram 1). Finally connect pin 5 of the sensors plug of all sensors.

Maintenance

microsonic sensors are maintenancefree. In case of excess caked-on dirt we recommend cleaning the white sensor surface.




Fig. 2: Assembly distances.

Notes

- The sensors of the pico+ family have a blind zone. Within this zone a distance measurement is not possible.
- Every time the power supply is switched on, the sensor detects its actual operating temperature and transmits it to the internal temperature compensation. The adjusted value is taken over after 120 seconds.
- In the normal operating mode, an illuminated yellow LED signals the object is within the adjusted window limits.
- If synchronization is activated the Teach-in is disabled (see »Further settings«, Diagram 1).
- The sensor can be reset to its factory setting (see »Further settings«, Diagram 1).
- Optionally all Teach-in and additional sensor parameter settings can be made using the LinkControl adapter (optional accessory) and the LinkControl software for Windows®.

Diagram 1: Set sensor parameters via Teach-in procedure

